

Biomass Utilization in Main Stream Power Systems

Galen Richards









- Overview of biomass experience at ALSTOM Power Inc.
- Retrofit of a bark-fired stoker boiler






Biomass-Fired CFB




Power Plant Laboratories




Biomass-Fired Stoker







Power Plant Laboratories



Pulverized Coal-Fired Boiler









* ALSTOM has over 100 boilers firing or cofiring biomass

Country	Customer Name	Station Name	Туре	Primary Fuels	Steam Flow k_lb/h
USA	S.D. Warren	Skowhegan	Suspension	Wood Waste, #6 Oil	660
USA	Stratton Energy	Stratton	Stoker	Bark	400
USA	Ultrapower	Rocklin	CFB	Biomass	220
USA	Ultrapower	Fresno	CFB	Biomass	220
USA	Temple Eastex Inc.	Evadale 2	Stoker	Bark	400
USA	Union Camp	Eastover	Suspension	Coal, #6 FO & Bark	400
USA	Union Camp	Savannah	Suspension	Coal, #6 FO & Bark	800



ALSTOM Biomass Experience ALSTOM

Country	Customer Name	Station Name	Туре	Primary Fuels	Steam Flow k_lb/h
Australia	Stanwell	Rocky Point	Stoker	Biomass, wood	130
Australia	Macquaire	Liddell	Suspension	Coal & sawdust	500 MWe
Vietnam	Tate & Lyle Sugar	Nghe An Tate	Stoker	Bagasse	320
Canada	MacKenzie	Finlay Forest	BFB	Wood & sawdust	228
Austria	Oesterreichische Draukraftwerke	St. Andra	Suspension	Coal & Wood	728
USA	Genessee	Flint	Stoker	Wood	330
USA	Osceola	Pahokee 1 & 2	Stoker	Bagasse	440
USA	Okeelanta	South Bay 1, 2 & 3	Stoker	Bagasse	440
USA	Colmac Mecca	Mecca 1 & 2	CFB	Biomass	232
USA	Scott Paper	Somerset 3	Stoker	Wood	700




Recent ALSTOM Biomass Boiler Sales







Plant	Fuel	Capacity	Commissioning (planned)
Landesbergen	Wood	20 MW + District Heating Option	April 2004
Zolling	Wood	20 MW + District Heating	April 2004
Emden	Wood	20 MW + District Heating Option	April 2005
Stapelfeld	Wood	20 MW + District Heating	April 2005
Delitzsch	Wood	20 MW	September 2004



Bark Cofiring with Coal

- Union Camp, Savannah Station
- 190 MWe
- Originally designed to cofire bark with coal







Wood Cofiring with Coal



- St. Andra power station, Austria
- 100 MWe lignitefired unit
- Retrofit to fire
 bituminous coal
 and 10% wood on
 hopper grate






Wood Cofiring with Coal



- Liddell Power
 Station, Australia
- 4-500 MWe coalfired units
- Fire up to 5% sawdust through the mills





Other Current ALSTOM Biomass Projects




- European unit cofiring pelletized straw with coal
- Recent RFP for unit that will fire 100% coal - 100% straw
- Coal-fired CFB wants to cofire biomass



Issues with Biomass Utilization




- Fuel preparation
- Fuel feeding
- Fuel variability
- Ash deposition
- Fly ash utilization
- Corrosion
- Erosion






VU-40 Stoker CFD Modeling & Retrofit











Power Plant Laboratories






- Reduce the Unburned Carbon Levels
- Reduce NOx & CO Emissions
- Increase Efficiency/Capacity
- Measure Pre and Post Conditions
- Minimize unit outage duration




Project Scope






Assessment: Pre-Retrofit

- Operation:
 - Limited Capacity
 - High Unburned Fines
 - Opacity during start-up
 - Erosion of ID fan & ductwork
 - Needed cinder reinjection
 - Difficulty burning wet bark
- Combustion System:
 - Ineffective air system
 - Leakage around stoker
 - Air heater leakage



Carryover (near rear wall)

Power Plant Laboratories







- Coupled Gas/Particle Steady-state solutions
- κ–ε turbulence model
- 2-step gas reaction chemistry
- Particles:
 - Bark and Char Reinjection groups
 - Prescribed non-spherical drag coefficients
- Heat extraction from walls, superheater & boiler banks
- FLUENT UDF for grate combustion




Grate Combustion Model






Bark Particle Size Distribution









Baseline Air Sources








HMZ[™] Nozzle Arrangement ALSTOM








Scope of Upgrade




- New ductwork
- HMZ[™] nozzles & flow dampers and seal boxes
- Pressure part modifications
- Air flow measuring devices
- Fabric stoker seal
- Air heater repairs



Predicted CO










Predicted O₂








Predicted Gas Temperature







Power Plant Laboratories



Boiler Performance Summary ALSTOM

		Original	Original	Upgrade	Upgrade
CONDITION	Units	Design	Operation	Design	Operation
Steam Flow	K lb/hr	350	365	400	430-480
Steam Temp	F	825	844	825	865
Steam Press	psig	850	850	850	850
Feedwater	F	295	266	295	265
Exit Gas Temp	F	400	?	495	575
Air to Furnace	F	495	470	495	575
Grate HHRR	MMBtu/hr-ft^2	1.080	1.100	1.234	1.330
Increase in Duty	%	-	7.5	15	29
Excess Air @TAH	%	33	45	25	25-30
Fuel Moisture	%	55	48.3	55	48.3
Overfire Air	%	40	20	45-50	50
Undergrate Air	%	60	80	50-55	50





- CFD modeling adequately simulates observed trends for stoker boilers
- Stoker retrofit decreased CO emissions and carbon in the fly ash while while operating at increased boiler load and lower excess air
- Many older stoker boilers may benefit from a retrofit

www.alstom.com

Information disclosed herein is furnished to the recipient solely for the use thereof as has been agreed upon with ALSTOM and all rights to such information are reserved by ALSTOM.

The recipient of the information disclosed herein agrees, as a condition of its receipt of such information, that ALSTOM shall have no liability for any direct or indirect damages including special, punitive, incidental, or consequential damages caused by, or arising from, the recipient's use or non-use of the information.